

TYPE APPROVAL CERTIFICATE

DNV·GL

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **40 153 - 01 HH**

Company **ilta inox S.p.A.**
Strada Statale 45 bis
26010 Robecco d'Oglio, ITALY

Product Description **Press fitting piping system consisting of 90/10 copper nickel alloy pipes and fittings with integral O-Ring including pressing tools**

Type **CUNIPRESS**

Environmental Category **None**

Technical Data /
Range of Application **Pipes/Fittings: Copper-Nickel alloy 90/10 acc. to UNS C 70600**
O-Ring quality: NBR (Brown)
M.A.W.P.: 13 bar (compressed air 10 bar)
Temperature range: - 20°C up to + 95°C
Pipe O.D.: 15 mm up to 108 mm

RANGE OF APPLICATION

The Chibro CUNIPRESS press fitting system is type approved for piping systems of pipe class III as specified in the GL Rules I-1-2 Machinery Installation, Table 11.14 - Compression Couplings - Press Type - Fire resistant type.

LIMITATIONS: Refer to page 2

Production place: ilta inox S.p.A. – Production Unit CHIBRO - Via Valtellina, 15, 22070 - Montano Lucino (CO) – Italy.

Test Standard **GL-VI-7-8 Test Requirements for Components and Systems of Mechanical Engineering and Offshore Technology, 2013.**

Documents **-Test report L.R.004/97/PM/rb/1;**
- Test report of product tests at Chibro dated 2001-02-23, 2010-07-15;
- Fire resistance test reports WTD 71 dated 2010-07-08;
- Product specification and catalogue;
- Type Approval assessment report (renewal) with hydraulic tests dated 2015-10-20.
- GL Approval ref. no. 15-047068, 15-071712.

Remarks **The selection of the pressing tools is to be in accordance with the manufacturer instructions.**

Valid until **2020-08-03**

Page **1 of 2**

File No. **II.C.08**

Hamburg, 2015-11-03

Type Approval Symbol



DNV GL

Hanspeter Raschle
Hanspeter Raschle

Plamen Dinkov
Plamen Dinkov

TYPE APPROVAL CERTIFICATE

DNV·GL

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **40 153 - 01 HH**

LIMITATIONS

The use of the CUNIPRESS press fitting system is not permitted in:

- Starting and control air piping systems arranged in machinery spaces of category A
- Not permanent water filled fire extinguishing systems
- Inert gas piping systems arranged in machinery spaces of category A, pump rooms and open decks

Valid until **2020-08-03**

Page **2 of 2**

File No. **II.C.08**

Hamburg, 2015-11-03

Type Approval Symbol



DNV GL

Hanspeter Raschle
Hanspeter Raschle

Plamen Dinkov
Plamen Dinkov